

FLAME EFFECTS BEFORE AN AUDIENCE PERMIT REQUIREMENT

1. A walk through demonstration of the flame effects shall be provided to Reno Fire Department before flame effects are approved.
2. Fire protection and life safety systems shall not be interrupted during the operation of the flame effects.
3. Operating instructions for the flame effect devices shall be on site.
4. All devices and materials shall have documentation describing the type of item and the performance specifications of the flame effect created. Documentation shall be available on site.
5. The premises shall be maintained in a neat and orderly manner.
6. A fire watch shall be provided during the performance and for a period of not less than ½ hour after the performance.
7. A minimum of two fire extinguishers with a rating of 2A10BC are required. The extinguishers must have current tags with the State of Nevada seal.
8. Smoking shall be prohibited in the area where fuels used in flame effects are present.
9. All other applicable sections of NFPA 160 shall be met.

Additional requirements for are subject to review and inspection of the event.